



Notes

Humidity Sensor configured for 0-5 vdc
 SW3 switches 1&3 up, 2&4 down.
 SW2 switch 3 down, all others up.